

FAILURE TO COMPLETE SIGNIFICANT DEFICIENCY CORRECTIVE ACTIONS

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

ESTE INFORME CONTIENE INFORMACIÓN IMPORTANTE ACERCA DE SU AGUA POTABLE. HAGA QUE ALGUIEN LO TRADUZCA PARA USTED, O HABLE CON ALGUIEN QUE LO ENTIENDA.

Ford City Water Municipal Water Works recently violated a drinking water requirement. Although this is not an emergency, as our customers, you have a right to know what happened, what you should do, and what we did (are doing) to correct this situation.

A routine inspection conducted on January 20, 2021 by the DEP found Failure to obtain amended permit & Public Water Supply permit.

We were required to take action to correct this deficiency. However, we failed to take this action by the deadline established by DEP.

What should I do?

- There is nothing you need to do. You do not need to boil your water or take other corrective actions. However, if you have specific health concerns, consult your doctor.
- If you have a severely compromised immune system, have an infant, are pregnant, or are elderly, you may be at increased risk and should seek advice from your health care providers about drinking this water. General guidelines on ways to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from EPA's Safe Drinking Water Hotline at 1-800-426-4791.

What does this mean?

This is not an emergency. If it had been, you would have been notified within 24 hours.

Inadequately treated water may contain disease-causing organisms. These organisms include bacteria, viruses, and parasites which can cause symptoms such as nausea, cramps, diarrhea, and associated headaches.

These symptoms, however, are not caused only by organisms in drinking water, but also by other factors. If you experience any of these symptoms and they persist, you may want to seek medical advice.

What is being done?

Minor permit amendments will be submitted in early 2023 along with a Major permit application for expanded water treatment.

We anticipate resolving the problem within 30 days (or the problem was resolved on _____).

For more information, please call Carol Fenyes of Ford City Municipal Water Works at 724-763-3081

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by Ford City Municipal Water Works.

PWS ID #: 5030005

Date distributed: January 3, 2023